

# NZEB IN THE LOCAL LOW-VOLTAGE GRID ENVIRONMENT IN DENMARK


ANNA MARSZAL, AALBORG UNIVERSITY  
AJM@CIVIL.AAU.DK

# Fossil Free Energy system





# Net ZEB

# Low-voltage network



- Source Net ZEB
- Residence
- Heat pump
- PV



# Net ZEBs details – type of house



BR 79 (140 kWh/m<sup>2</sup>.yr)

$U_{\text{walls}} = 0.32 \text{ W/m}^2\cdot\text{K}$

Natural ventilation 0.4 ACH

Infiltration 0.2 ACH


Thermal mass: light (44 Wh/K.m<sup>2</sup>)

$\tau = 27 \text{ hrs}$

Heating set-point: 20°C

Design power: 70 W/m<sup>2</sup>

Primary water tmp: 70°C radiator, 43°C UH



Passive house (14 kWh/m<sup>2</sup>.yr)

$U_{\text{walls}} = 0.09 \text{ W/m}^2\cdot\text{K}$

Mechanical ventilation 0.4 ACH ( $\eta = 0.8$ )

Infiltration 0.07 ACH


Thermal mass: medium (53 Wh/K.m<sup>2</sup>)

$\tau = 105 \text{ hrs}$

Heating set-point: 21°C

Design power: 25 W/m<sup>2</sup>


Primary water tmp: 45°C radiator, 30°C UH



# Net ZEBs details – appliances

## Main characteristics:

- Empirical-probabilistic bottom-up approach model
- Minimum resolution 1-min
- 35 household appliances (heavy electrical loads e.g. heat pumps not included)
- Single family houses with 1-5 occupants and 3 types of households electricity use (low, medium, high)



# Net ZEBs details – PV

## Main characteristics:

- Minimum resolution 1-min
- Size 20-50 m<sup>2</sup> (P<sub>max</sub> 6kW)
- PV power output:


$$P_g = A_c I \eta_{mp} \eta_a \text{ [W]}$$

- Maximum power-point efficiency of PV

$$\eta_{mp} = \eta_{STC} \left[ 1 + \mu (T_a - T_{c,STC} + I \frac{T_{c,NOCT} - T_{a,NOCT}}{I_{NOCT}}) (1 - \eta_{STC}) \right]$$

- Conversion efficiency at STC

$$\eta_{mp} = \frac{P_{STC}}{I_{STC} A_{ref}}$$




# LV network details

## Main characteristics:

- The ZEB are only appointed at residential level
- From an electrical perspective, the users living in ZEB are represented by power consumption and generation profiles with 1 min resolutions:
  - Load:
    - CL (1 hour based) – Original provided by the DSO
    - CL (1 min based)
    - HP (1 h based)
  - Generation:
    - PV (1 min based)
    - WP (1 min base) – Not yet


## Power Distribution Operation :

- Power Lines and Transformers should not be loaded more than 80 % at any time.
- European Standard EN 50160: maximum voltage deviation  $\pm 10\%$  at any bus of the MV and LV system. According to the DSO experience  $\pm 6\%$ .



# RESULTS


## FIRST WEEK OF FEBRUARY - 1 HOUR BASED PROFILES






# PRELIMINARY RESULTS

## FIRST WEEK OF FEBRUARY – 1 MIN BASED PROFILES




# Results

## FIRST WEEK OF FEBRUARY – 50% OF PV



## SECOND WEEK OF JULY – 50% OF PV



# Conclusions

- High resolution investigation shows the full picture
- More complex LV network operation
- In high latitudes due to revers flow 2 different LV operation strategies for winter and summer
- Single Net ZEB does not create a problem but a group of Net ZEBs connected to a single power line influences the LV network and transformer performance

THANK YOU



AALBORG UNIVERSITY  
DENMARK